

Waste-to-Energy Technologies and Applications




E²S² Conference

**Jerry Davis
May 10, 2011**

Overview

- ▶ Technology Overview
- ▶ Commercial and Emerging Applications
- ▶ Driving Factors for Waste-to-Energy (WTE)
- ▶ Variables to Consider for WTE Projects
- ▶ Hybrid Plant Study

Energy Pathways



- Heat/power/CHP
- Boiler, steam turbine
- Co-fire with coal


- Burn gas for hot water/steam (commercial)
- Use in IC engine for CHP (pre-commercial)
- Catalytic conversion to alcohols, chemicals, synthetic diesel (development)

- Torrefied wood for pellets, coal replacement
- Pyrolysis oil for boilers and power (early commercial)
- Specialty chemicals (commercial)
- Further refining for transportation fuels (development)

Combustion Overview

- 86 existing commercial facilities combust 26 million tons of MSW per year in 24 states.
- Typical minimum for feasibility is 300 tons per day (tpd)

Typical Mass Burn WTE Layout




Avg. Emissions Profile: U.S. WTE Plants

Pollutant	Average emission	US EPA standard	Average emission (% of US EPA standard)	Unit
Dioxin/furan, TEQ basis	0.05	0.26	19.2%	ng/dscm
Particulate matter	4	24	16.7%	mg/dscm
Sulfur dioxide	6	30	20%	ppmv
Nitrogen oxides	170	180	94.4%	ppmv
Hydrogen chloride	10	25	40%	ppmv
Mercury	0.01	0.08	12.5%	mg/dscm
Cadmium	0.001	0.020	5%	mg/dscm
Lead	0.02	0.20	10%	mg/dscm
Carbon monoxide	33	100	33.3%	ppmv

dscm: dry standard cubic meter of stack gas.

Source: C.S. Psomopoulos et al (2009), Waste Management 29, 1718-1724)

Combustion: Emissions Profile




* Source: C.S. Psomopoulos et al (2009), Waste Management 29, 1718-1724


** Source: Themelis, N.J. (2007), Thermal treatment review, Waste Management World (July-August), 37-45

Gasification Overview


Exothermic/Combustion Reaction



Endothermic/Gasification Reactions



Example of Biomass Gasifier



Gasification Emissions Profile: Kinsei Technology

Item Tested	Location	Test Result	Unit	EPA Standard	Princeton vs EPA
Particulate	Stack	00.0014	gr/dscf	0.0015	10% lower
CO	Stack	32.2	ppmv	100	60% lower
HC	Stack	Not detectable	ppmv	10	99% lower
NOx	Stack	66.81	ppmv	150	60% lower
SO ₂	Stack	15.88	ppmv	30	50% lower
HCl	Stack	12.068	ppmv	25	50% lower
Cl ₂ + HCl		9.068	ppmv	21	60% lower
Hg/	Stack	0.0081	ug/m ³	8.1	99% lower
Dioxin /Furan	Stack	0.098	ngTEQ/dscm	0.11	10% lower
Opacity	Stack	10%		10%	Same

Source: Princeton Environmental

- About 25 units operable in the U.S. using waste material feedstocks, including biomass
- Primary challenge for WTE application is inconsistency of MSW as feedstock

Gasification Flexibility

Primary Feedstock

Biomass


MSW

Others

Gasification

Syngas
(CO+H₂)

Products



Commercial Applications

- Large scale (>300 tpd) combustion units commercially viable
 - Economy of scale due to high capital cost of emissions control equipment
 - Almost all commercial power systems are combustion/steam turbine
 - Efficiencies in 15% – 30% range power only, (60% – 70% CHP)
 - 550-650 kWh per ton of MSW
 - Stoker and fluidized bed boilers
 - Avg. size in the U.S. is 20 MW
 - Installed cost: \$4,000 per kW
 - Residual material (ash) about 10% by volume, 20% by weight
 - LCOE = \$0.06 – \$0.20 per kWh (depends on tipping fee revenue)



Emerging WTE Applications

- Small scale (10 – 300 tpd) advanced conversion technologies in demonstration phase
 - Potentially better suited to small scale applications
 - More efficient than combustion, 30% – 40%
 - 600 – 800 kWh per ton of MSW
 - Syngas can be used in IC engines, gas turbines, steam turbines or to make liquid fuels
 - Potential for reduced water usage
 - Installed cost: \$6,000+ per kW
 - Residual material about 10% by volume, 20% by weight
 - LCOE = \$0.15 – \$0.20+ per kWh
(LCOE depends on tipping fee revenue)



IES 30 tpd unit Mecca, CA

Emerging WTE Applications

- Expeditionary scale (.5 – 3 tpd) WTE entering limited demonstration phase
 - Demonstration projects at Fort Irwin, Aberdeen Proving Grounds, Edwards Air Force Base
 - Potential forward operating base (FOB) applications
 - Estimated loads of .32 KW – .8 KW per person
 - 3 – 18 lb of waste generated per person per day
 - 250 – 600 kWh per ton MSW
 - WTE may provide 7 – 38% of the power requirement




Community Power Corp: MEWEPS System

Driving Factors: DoD Installations

- Cost
 - National average solid waste disposal cost is \$44 per ton
 - Lifecycle costs for DoD landfills can exceed \$100 per ton
- Space
 - 71 active landfills on DoD installations; these are quickly reaching capacity
 - 400 closed landfills occupy over 5000 acres; may be possible to “mine” these landfills for WTE and recover the land for use
 - Currently not considered diversion per DoD’s Integrated Solid Waste Management plan (a challenge for net zero waste goals)
- Energy
 - WTE contributes to renewable energy generation and greenhouse gas reduction executive orders and goals

Driving Factors: Operational Energy

- Fully Burdened Cost of Waste Disposal
 - \$500 per ton
- Government Accountability Office (GAO) Report
 - 251 burn pits in Afghanistan, 21 in Iraq as of Aug. 2010
 - Poor air quality: Over 90% of air samples exceeded Military Exposure Guidelines for particulate matter (see graph below)
 - Lawsuits filed in 43 states against Government waste management contractors




Source: GAO analysis of DOEHRIS ambient air sampling data.

Evaluating Opportunities: Variables

- Waste stream
 - Large-scale, commercially proven, systems require >300 tpd
 - For a DoD installation, this requires partnership with a local municipality
 - Small-scale, yet-to-be proven systems can operate with smaller waste streams
 - Possible use of plasma arc gasification for destruction of medical or hazardous waste improves WTE project economics
- Solid waste disposal cost
 - Coastal or island locations typically favorable due to land constraints and high costs to build new landfills
 - Over \$70/ton may support WTE
- Energy costs
 - Over \$.12/kWh is favorable for WTE

WTE – CSP Integrated Plant Study

- Based on 320,000 tons per year (approximately 1000 tpd) with an 85% capacity factor
- WTE (mass burn) and concentrating solar power (CSP) providing heat for a common steam cycle
- LCOE about 11¢/kWh
- Scenario 1: Low-level solar contribution for consistent generation
 - Solar contribution makes up 12% of annual generation
- Scenario 2: High-level solar contribution for increased peak generation
 - Solar contribution makes up 26% of annual generation



Contact Info

Jerry Davis

Senior Engineer

Deployment & Market Transformation

National Renewable Energy Laboratory

1617 Cole Blvd, MS:RSF-402

Golden, CO 80401

303-275-3199

Jerry.Davis@nrel.gov